



Certificate of constancy of performance  
No. 1325-CPR-3874

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product(s)

**Openable wooden windows with fire resistance properties**  
FT/EI 92.48 and IV92 EI 30  
according to the Annex

PLACED ON THE MARKET UNDER THE NAME OF:

**SIA "ARBO Windows"**

Kustes dambis 32, Ventspils, LV-3601, Latvia, Reg. No. 50103451301

ADDRESS OF MANUFACTURER:  
SIA "ARBO Windows" factory, Kustes dambis 32, Ventspils, LV-3601, Latvia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 16034:2014**  
and  
**EN 14351-1:2006+A2:2016**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 2 December 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by notified factory production control certification body.

*(next surveillance – December 2024)*

11 December 2023

**Mārtiņš Maskavs**  
Certification Manager



Certificate issued on 1 (one) page with Annex on 1 (one) page



EN ISO/IEC 17065  
S1-182

**AS Inspecta Latvia**  
Skanstes iela 54A, Rīga  
LV-1013, Latvija

T. +371 67 607 900  
F. +371 67 607 901  
[lat.la@kiwa.com](mailto:lat.la@kiwa.com)

[www.kiwa.com](http://www.kiwa.com)

**Inspecta Latvia**  
Trust, Quality & Progress

CERTIFICATE



**Manufacturer:** SIA "ARBO Windows", Kustes dambis 32, Ventspils, LV-3601, Latvia

**Product:**

1. Openable wooden windows with fire resistance properties FT/EI 92.48

No.	Declared property	FT/EI 92.48
1.	Fire resistance	EW60
2.	Smoke control	S <sub>200</sub> , S <sub>a</sub>
3.	Disconnecting ability	released
4.	Self-closing	C
5.	Disconnecting ability resistance	release maintained
6.	Self-closing resistance Cyclicalty Corrosion resistance	0 pass
The windows may be modified in accordance with the conditions mentioned in the GTC (Lithuania) report No. 59-6.2021.1 (22.11.2021.)		

2. Openable wooden windows with fire resistance properties IV92 EI 30

No.	Declared property	IV92 EI 30
1.	Fire resistance	EW30 EI <sub>1</sub> 30 EI <sub>2</sub> 30 E30
2.	Smoke control	S <sub>200</sub> , S <sub>a</sub>
The windows may be modified in accordance with the conditions mentioned in the GTC (Lithuania) report No. 59-2.2022.1 (05.05.2022.)		

11 December 2023

**Mārtiņš Maskāvs**  
Certification Manager



EN ISO/IEC 17065  
S1-182

**AS Inspecta Latvia**  
Skanstes iela 54A, Rīga  
LV-1013, Latvija

T. +371 67 607 900  
F. +371 67 607 901  
latvia@kiwa.com

[www.kiwa.com](http://www.kiwa.com)