



Certificate of constancy of performance
No. 1325-CPR-3874

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product(s)

Openable wooden windows with fire resistance properties
FT/EI 92.48 and IV92 EI 30
according to the Annex

PLACED ON THE MARKET UNDER THE NAME OF:

AS "ARBO Windows"

Kustes dambis 32, Ventspils, LV-3601, Latvia, Reg. No. 50103451301

ADDRESS OF MANUFACTURER:

AS "ARBO Windows" factory, Kustes dambis 32, Ventspils, LV-3601, Latvia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 16034:2014
and
EN 14351-1:2006+A2:2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 2 December 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by notified factory production control certification body.

(next surveillance – December 2025)

16 December 2024

Mārtiņš Maskavs
Certification Manager



Certificate issued on 1 (one) page with Annex on 1 (one) page



EN ISO/IEC 17065
S1-182

AS Inspecta Latvia
Skanstes iela 54A, Rīga
LV-1013, Latvija

T. +371 67 607 900
F. +371 67 607 901
latvia@kiwa.com

www.kiwa.com

Inspecta Latvia
Trust, Quality & Progress

CERTIFICATE

Annex

Certificate No. 1325-CPR-3874



Manufacturer: AS "ARBO Windows", Kustes dambis 32, Ventspils, LV-3601, Latvia

Product:

1. Openable wooden windows with fire resistance properties FT/EI 92.48

| No. | Declared property | FT/EI 92.48 |
|-----|--|-----------------------------------|
| 1. | Fire resistance | EW60 |
| 2. | Smoke control | S ₂₀₀ , S _a |
| 3. | Disconnecting ability | released |
| 4. | Self-closing | C |
| 5. | Disconnecting ability resistance | release maintained |
| 6. | Self-closing resistance Cyclicality Corrosion resistance | 0 pass |

The windows may be modified in accordance with the conditions mentioned in the GTC (Lithuania) report No. 59-6.2021.1 (22.11.2021.)

2. Openable wooden windows with fire resistance properties IV92 EI 30

| No. | Declared property | IV92 EI 30 |
|-----|-------------------|---|
| 1. | Fire resistance | EW30 EI ₁ 30 EI ₂ 30 E30 |
| 2. | Smoke control | S ₂₀₀ , S _a |

The windows may be modified in accordance with the conditions mentioned in the GTC (Lithuania) report No. 59-2.2022.1 (05.05.2022.)

16 December 2024

Mārtiņš Maskavs
Certification Manager



EN ISO/IEC 17065
S1-182

AS Inspecta Latvia
Skanstes iela 54A, Rīga
LV-1013, Latvija

T. +371 67 607 900
F. +371 67 607 901
latvia@kiwa.com

www.kiwa.com